

MODEL CERTIFICATE OF TESTING OF A FIRE DETECTION AND ALARM SYSTEM

Section 1

Occupier/Owner (Block Caps) _____

Name and Address of Premises _____
(Block Caps) _____

Telephone No. _____



See Note below

Section 2 (tick as appropriate)

The system is operational and has been checked and tested in accordance with **I.S. 3218: 2013** (Fire Detection & Alarm Systems for Buildings). Any variations from this standard have been listed below (X).

- | | | | |
|---|----------------|--|--------------------------|
| - | Clause 8.5.2 | Extensions and Alterations to Existing Systems | <input type="checkbox"/> |
| - | Clause 9.2.2.5 | Quarterly Inspection and Test | <input type="checkbox"/> |
| - | Clause 9.2.2.6 | Annual Inspection and Test | <input type="checkbox"/> |
| - | Clause 9.2.3.2 | Servicing after a Fire | <input type="checkbox"/> |
| - | Clause 9.2.3.3 | Servicing Following a False Alarm | <input type="checkbox"/> |
| - | Clause 9.2.3.4 | Servicing Following a Fault | <input type="checkbox"/> |
| - | Clause 9.2.3.5 | Servicing Following a Pre-alarm Warning | <input type="checkbox"/> |
| - | Clause 9.2.3.6 | Servicing Following a period of disconnection | <input type="checkbox"/> |
| - | Clause 9.2.3.7 | Other Non-routine Attention (Specify) | <input type="checkbox"/> |

Tick Box as appropriate:

- | | Yes | No | N/A |
|---|--------------------------|--------------------------|--------------------------|
| ▪ Detectors in all rooms and circulation areas and spacing and siting of heat and smoke detectors are in accordance with Clause 6.10.4 of I.S. 3218: 2013. | <input type="checkbox"/> | <input type="checkbox"/> | |
| ▪ Current system in premises is a: L1 <input type="checkbox"/> or L2/L3 <input type="checkbox"/> or L3 <input type="checkbox"/> | | | |
| ▪ System interconnected with private accommodation (X) see Clause 5.2 of I.S. 3218: 2013. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| ▪ Minimum sound level of either 65dB(A) or 5 dB (A) above any other noise likely to persist for a period longer than 30 seconds, whichever is greater, is provided in all accessible areas of the premises See Clause 6.6.4.1 of I.S. 3218: 2013. | <input type="checkbox"/> | <input type="checkbox"/> | |
| ▪ The minimum sound level is 75-dB (A) at the bed head with all doors shut, in areas where sleeping persons are accommodated. See Clause 6.6.4.1 of I.S. 3218: 2013. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| ▪ Manual call points are located in accordance with Clause 6.7 of I.S. 3218: 2013. | <input type="checkbox"/> | <input type="checkbox"/> | |
| ▪ A Schedule of Service (as Annex D2) has been completed & fixed adjacent to the Fire Alarm Panel. | <input type="checkbox"/> | <input type="checkbox"/> | |

Any person who wilfully or recklessly gives to an Authorised person or Fire Authority, information which is false or misleading, shall be guilty of an offence and as such may be liable to prosecution.

See Note below

Section 3

If 'No Box' ticked for any of the above - provide details in order to arrange for an authorised Officer to inspect the premises.

Name of person responsible for Inspection and Test (block Capitals) -see "Note" below: _____

I/We hereby certify that the smoke/heat alarm system at the above premises has been serviced & tested in accordance with Section 9.2 of I.S. 3218: 2013. I/We confirm my/our competence to undertake this work.

Signature of person responsible for Inspection and Test: _____ Date: _____

Position: _____ Phone: _____ For and on behalf of (company) _____

(X) Details of any variations from the Code of Practice (I.S. 3218: 2013) - attach additional page(s) if required;

NOTE: -

The Owner/occupier should ensure that the person carrying out the inspection is Competent and has received adequate instruction to complete the task. Furthermore, you should be aware that Under Section 11 of the Building Control Act, 1990 and Sections 18 and 22 of The Fire Services Act, 1981 and 2003, an inspection may be implemented by an Authorised Officer to ensure that the information provided above is true. Any person who wilfully or recklessly gives to an Authorised person or Fire Authority information, which is false or misleading, shall be guilty of an offence and as such may be liable to prosecution.